


Tender Notice No....130.....

Date: 30./04./2024.

**Mahavir Cancer Sansthan And Research Centre, Patna**

**Tender Notice**

Sealed Quotation are invited for Supply, Installation, Testing & Commissioning of Ductable Air Conditioning System with built in mechanism i.e heaters with auto sensor or inbuilt dehumidifier in air supply ducts to control the humidity automatically throughout the year. the AC ducts termination to the magnet Room should be with Canvas connections. Four opening of 618 X 199.1 mm will be provided for air supply and return. two opening out of four can be used for the air supply and remaining two can be used for return air. The AC Ducting should be made out of Aluminium. AC System should maintain the indoor room temperature of 20 degree Celsius - 24 degree Celsius of Magnet Room, Console Room, Technical Room & Waiting Room of MRI UNIT at Mahavir Cancer Sansthan, Patna. Total Area of MRI Unit is around 1200 SFT and The Heat Load of equipment would be around 15 KW. The Quotation should reach within 7 working days from date of issue of NIT by courier , registered post or drop into the tender box (Room no. 03)-A Block mentioning therein the terms and conditions addressed to the Director Mahavir Cancer Sansthan Phulwarisharif, Patna 801505 .Tender number should be mention on top of the sealed envelope, Quotation may pre visit the site as per his convenience. The Sansthan reserves the right to reject any or all tenders without assigning any reason thereof.

  
Director (Admin.)  
Mahavir Cancer Sansthan


Tender Notice No...131.....

Date: 30.1.04./2024.

**Mahavir Cancer Sansthan And Research Centre, Patna**

**Tender Notice**

Sealed Quotation are invited for Supply, Installation, Testing & Commissioning of Ductable Air Conditioning System with built in mechanism i.e heaters with auto sensor or inbuilt dehumidifier in air supply ducts to control the humidity automatically throughout the year. AC System should maintain the indoor room temperature of **20 degree Celsius - 24 degree Celsius of HDU Unit (3<sup>rd</sup> Floor ,A-Block)** at Mahavir Cancer Sansthan, Patna. Total Area of HDU Unit is around **1500SFT**. The Quotation should reach within 7 working days from date of issue of NIT by courier , registered post or drop into the tender box (Room no. 03)-A Block mentioning therein the terms and conditions addressed to the Director Mahavir Cancer Sansthan Phulwarisharif, Patna 801505 .Tender number should be mention on top of the sealed envelope, Quotation may pre visit the site as per his convenience. The Sansthan reserves the right to reject any or all tenders without assigning any reason thereof.

  
Director (Admin.)

**Mahavir Cancer Sansthan**